


Example of useful **AHU BACnet ODS**



Black	Value/Status
Green	Setpoints/Command
Red	Alarm
Blue	Actual setpoint-value

ODS

Counter-flow
heat exchanger

ST41	5922	Heat recovery output signal
ST42	11421	Heat recovery output signal defrost damper
ST43	46813	Heat recovery output signal defrost damper
GP8	31088	Act.pressure over Counter- flow heat exchanger
	46503	Defrost Active
	64168	Normal pressure calculated
	41115	Actual start pressure defrost
	36716	Actual stop pressure defrost